

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Red Sky Ranch WTP

## High Levels of Total Trihalomethanes (TTHM)

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. On 11/30/2022 we were notified that our system exceeds the maximum contaminant level (MCL) for Total Trihalomethanes (TTHM). **The MCL is 80 ug/L. The average level over the last year is 82.1 ug/L. The result from the 11/8/2022 sample 25.8 ug/l. This is below the MCL but we are still above the running average for the previous 4 quarters.**

### What does this mean? What should I do?

- **You may want to use an alternative drinking water supply (e.g. bottled). If you have specific health concerns, consult your doctor.**
- Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.
- If you have an infant, severely compromised immune system, are pregnant, or are elderly, you may be at increased risk and should seek advice from your doctor about drinking this water. General guidelines on ways to lessen the risk of infection by bacteria and other disease-causing organisms are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

### What is being done?

1. Water flushing and bleeding has been increased to decrease the water age in the system.
2. New GAC has been installed into the #1 and #2 vessel at the WTP.
3. An engineer is evaluating the existing system. A pilot study is being conducted 12/8/2022 to determine we are using the most effective granular activated carbon for our source water.
4. \*New GAC was installed in vessel #2 on 9/3/2022.
5. \*A THM volatilization system will be installed in tank #2. We are hoping to have this complete by November 2022. The system is designed to remove 50% to 60% of TTHM.

We anticipate resolving the problem by **3/30/2023**. For more information, please contact **John Volk** at **jvolk@wqcpllc.com** or **970-389-4491**, or **28 Second St, Suite 213 Edwards, CO 81632**.

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and*

*businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\**

This notice is being sent to you by: Red Sky Ranch WTP - CO0119673  
Date distributed: **12/8/2022**